

NOTICE

All the members are informed that in Residential Building a generator set may be installed as per following:

1. Generator set to be installed in basement or front lawn 5 ft. away from common boundary walls.
2. Generator set must be installed with sound proof canopy and noise beyond the boundary limit shall not be more than 15 decibel.
3. Maximum capacity of generator set is 25 KVA.
4. Generator set will not be used as prime supply but only in failure of WAPDA / LESCO power supply.

Note:

This supersedes all previous rulings / notice on this subject.

Secretary Technical & Chief Engineer
Defence Housing Authority
Lahore Cantt.,
02 May 2012